



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 187009 - 2500000026 (LR 108985)

Project: 2500000026

Date Issued: January 14, 2000

Issued to: **Relcom Inc.**
2221 Yew Street
Forest Grove, OR 97116
USA

The products listed below are eligible to bear the CSA Mark shown



Issued by: Andrew Redeker, C.E.T.

Signature: *P Andrew Redeker*

CLASS

2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

PRODUCTS

Class I, Division 1, Groups A, B, C and D

“SpurGaurd” Models FCS-SG-20, FCS-SG-40 and FCS-SG-60; T-Code T3; I.S. Entity (see parameters below) when installed as per Installation Instructions issued 99/10/29.

Gas Groups

| | <u>A, B</u> | <u>C</u> | <u>D</u> |
|-----|-------------|----------|----------|
| Voc | 22V | 22V | 22V |
| Isc | 224mA | 575mA | 781mA |
| Ca | 0uF | 0uF | 0uF |
| La | 0uH | 0uH | 0uH |

APPLICABLE REQUIREMENTS

- CSA Standard C22.2 No 0-M1991 - General Requirements - Canadian Electrical Code Part II.
- 157-M1992 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations.