

FM Approvals 1151 Boston-Providence Tumpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781 762 9375 www.tmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

AS-i Megablock Part number A10a-b. Actuator Sensor Interface.

NI / I / 2 / ABCD / T4, Ta = 70 °C I / 2 / IIC / T4, Ta = 70 °C

a = Actuator Sensor Interface Series: 0, 1, 2, 3

b = Connection Interface: None, PC, PD

Special Condition for use;

- 1. The AS-i Megablock shall be installed in compliance with the enclosure, mounting, and spacing, and segregation requirement of the ultimate application
- 2. When installed in Division 2 Hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables must not be removed or inserted unless the area is known to be non-hazardous.

Equipment Ratings:

Suitable for Class I, Division 2, Groups A, B, C, and D and Class I, Zone 2, Group IIC indoor Hazardous (Classified) Locations

Approved for:

Relcom Inc. Forest Grove, OR





This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600

1998

Class 3611

1999

Original Project ID: 3019356

FM Approval Granted: March 19, 2004

Subsequent Revision Reports / Date FM Approval Amended

Report Number

Date

Report Number

Date

FM Global Technologies LLC

David W. Styrcula

Technical Team Manager

3/24/04