



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

FBT-6-a Fieldbus Network Monitor

IS / I / 1 / ABCD / T4 Ta = +50°C - 501-353; Entity; FISCO
I / 0 / Ex ia IIC T4 Ta = +50°C - 501-353; Entity; FISCO
IPA / I / 2 / ABCD / T4 Ta = +50°C - 501-353; NIFW, FNICO
I / 2 / IIC / T4 Ta = 50°C - 501-353; NIFW, FNICO

a = PA or blank

Entity parameters

V_{max} = 24V
I_{max} = 250mA
C_i = 0
L_i = 0
P_i = 1.2W
V_{oc} = 0
I_{sc} = 0

FISCO parameters

V_{max} = 17.5V
I_{max} = See Table
P_i = 5.32W
C_i = 0
L_i = 0
V_{oc} = 0
I_{sc} = 0

Nonincendive Field Wiring parameters

V_{max} = 32V
C_i = 0
L_i = 0
V_{oc} = 0
I_{sc} = 0



Member of the FM Global Group

FNICO parameters

Vmax = 17.5V

I_{max} = See Table

C_i = 0

L_i = 0

V_{oc} = 0

I_{sc} = 0

	Division 1	Division 2
Groups A,B	183 mA	274 mA
Groups C, D	380 mA	570 mA

	Zone 0 and 1	Zone 2
Group IIC	183 mA	274 mA
Group IIB, IIA	380 mA	570 mA

Special conditions of use

1. *The USB connector shall only be connected to other apparatus when the FBT-6 is located in an unclassified location.*

Equipment Ratings:

Intrinsically safe for Class I, Division 1, Groups A,B,C,&D and Class I, Zone 0, Group IIC when used in accordance with the Entity and FISCO concepts and Control Drawing 501-353. Temperature Class T4 at an ambient of 50°C

Nonincendive for Class I, Division 2, Groups A, B, C, & D and Class I Zone 2 when used in accordance with the NIFW and FNICO concepts and Control Drawing 501-353. Temperature Class T4 at an ambient of 50°C.

FM Approved for:

Relcom Inc, 2221 Yew St, Forest Grove OR 97116



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No. 157	1992
C22.2 No. 213	1987
CAN/CSA-E79-0-95	1995
CAN/CSA-E79-11-95	1995

Original Project ID: 3028840

Approval Granted: March 8, 2007

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
Reissued	10/14/11		

FM Approvals LLC

Timothy Adam
Technical Team Manager

October 14, 2011
Date