



FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

**F802. Fieldbus Supply Module and Carriers.**

NI/1/2/ABCD/T4 Ta = 65°C

I/2/IIC/T4 Ta = 65°C

NI/1/2/ABCD/T4 Ta = 50°C (>60% Load)

I/2/IIC/T4 Ta = 50°C (>60% Load)

**Fieldbus Power Supply Module: F802**

**Fieldbus Supply Module and Carriers Combination Part Numbers:** F822-2-PS, F822-2-PS-NR, F822-2-PC, F822-2-PC-NR, F880-2-PS, F880-2-PS-NR, F880-2-PC, F880-2-PC-NR, F880-2-LS, F880-2-LS-NR, F880-2-LC, F880-2-LC-NR, F880-2-RS, F880-2-RS-NR, F880-2-RC, F880-2-RC-NR, F882-2-PS, F882-2-PS-NR, F882-2-PC, F882-2-PC-NR, F890-2-PS, F890-2-PC, F890-2-PS-NR, F890-2-PC-NR, F892-2-PS, F892-2-PC, F892-2-PS-NR, F892-2-PC-NR, F880-CA, F880-CL, F880-CR, F890-CA, F892-CA,

**Special Conditions of Use:**

1. The F802 Fieldbus Supply Module and Carriers shall be installed in compliance with the enclosure, mounting, spacing, and segregation requirements of the ultimate application, including a tool removable cover.
2. When installed in hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables or Fieldbus Supply Modules must not be removed or inserted unless the area is known to be non-hazardous.
3. It is the responsibility of the manufacturer to provide warning markings in French where required by local jurisdictions..

**Equipment Ratings:**

Nonincendive for Class I, Division 2, Groups A, B, C, and D and Class I, Zone 2, Group IIC hazardous locations.

FM Approved for:

Relcom Inc.  
Forest Grove, OR, USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA-C22.2 No 213	1987
CSA-C22.2 No 1010.1	2004


Original Project ID: 3033657C

Approval Granted: 12/30/2008

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
100526	June 10, 2010		

FM Approvals LLC

  
\_\_\_\_\_  
J.E. Marquardt  
Group Manager, Electrical

10 June 2010  
Date