

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com



CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

"Megablock" Models F100, FCS-MB2cba, FCS-MB4cba, FCS-MB8cba, FCS-MB10cba, FCS-MB12cba, F118a, F200a-F203a, F205a-F207a, F209a-F211a, and F213a-F215a.

NI/II/2/ABCD/T4 Ta = 70°C – 500-275

Ex nA IIC T4 Ta = 70°C – 500-275

a = Connector type: -PC, -PD or blank

b = Terminator: -T or blank

c = Spurguard: -SG or blank

Special Condition of Use - The equipment shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Equipment Ratings:

Class I, Division 2, Groups A, B, C, D, T4, Tambient = 70°C; Ex nA IIC T4, Tambient = 70°C; install per drawing 500-275

FM Approved for:

Relcom, Inc.
Forest Grove, OR 97116



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 213	1987
CSA E60079-0	2002
CSA E60079-15	2002
CSA C22.2 No. 1010.1	1992
(Including Amendment 2)	1997

Original Project ID: 3013269

Canadian Project ID: 3039410C

Approval Granted: *May 25, 2010*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

J.E. Marquedan
Group Manager, Electrical

25 May 2010
Date